

Resource Management: Assessing the Warm Water Facilities and Systems Supporting ORNL's Summit

Jim Rogers

Director, Computing and Facilities National Center for Computational Sciences Oak Ridge National Laboratory

ORNL is managed by UT-Battelle, LLC for the US Department of Energy



ORNL Leadership Class Systems 2004 - 2018



ORNL's Transition to Warmer Facility Supply Temperatures



Motivation for "Warmer" Cooling Solutions Serving HPC Centers

- Reduced Cost, Both CAPEX and OPEX
 - Reduce or eliminate the need for traditional chillers.
 - No chillers, no ozone-depleting refrigerants (GREEN)
 - Oak Ridge calculates an annualized PUE for air--cooled devices of no better than 1.4 (ASHRAE Zone 4A – Mixed Humid)



- HPC power budgets continue to grow Summit has a design point for >12MW (HPC-only). Minimizing PUE/ITUE is critical to the budget.
- Easier, more reliable design
 - Design is reduced to pumps, evaporative cooling, heat exchangers.

– Traditional chilled water may not be necessary at all (NREL, NCAR, et al)

OLCF Facilities Supporting Summit

- Titan 9MW @ heavy • load
- Sitting on 250 pounds/ft2 raised floor
- Uses 42F water and • special CDUs (XDPs)
- Summit 256 compute cabinets on-slab
- 100% room-neutral design uses RDHX
- 20MW warm-water cooling plant using centralized CDU/secondary loop

Soutional Laboratory



21°C/20MW/7700 ton Facility System Design System

- Summit
 - Demand: 3.3 (idle)-11.5MW;
- Secondary Loop
 - Supply 3300GPM (12,500 liters/min) @ 21°C; Return @ 29 33°C
 - CPUs and GPUs use cold plates
 - DIMMs and parasitic loads use RDHX
 - Storage and Network use RDHX





South Computing Research Computing

Medium Water Temperature Cooling Design

Primary Loop uses Evaporative Cooling Towers (~80% of the hours of the year)

When the MTW RETURN is above the 21C setpoint, use a second set of Trim HX (with 5.5C on the other side) to drive MTW to the 21C setpoint.

The need for the trim-loop is about 20% of the hours in the year, and can ramp 0-100% to meet the setpoint back to Summit

A New Challenge – Titan and rotated off-line, so there is no significant load on the Chillers[1-5]. NOAA moved to the warm water loop (~500GPM demand)

COAK RIDGE LEADERSHIF

Existing chilled water cooling loop 64-71°F 90-101°F -**Cooling Tower 2** MTWPs **CHILLER 1 Cooling Tower 1** 42-48°F **CHILLER 2 CHILLER 3 CHILLER 4** Trim Econo HXs HXs CHILLER 5 CTWPs CHWPs New primary cooling loop 59-87°F 54-58°F Revision: 2 - Date: 5/7/15 ORNL 2015-G00355/DLR





Benefits of ORNL's Warm-Water (21°C) Mechanical Plant

Warm Water

- Total Capacity to manage 20MW of IT load
- Warm Water allows annualized PUE of 1.1
 - For each ~\$1M cost per MW-year for consumption on Summit;
 - A corresponding ~\$100k cost per MW-year for waste heat management
- Titan was \$6-7M/year plus \$1.8-\$2M to remove the waste heat
- Summit will have a similar "power bill", but closer to \$500k annually for waste heat.

Integrated System/Facility Operation

- Integration with the PLC allows us to tune
 water pressure and flow
 - Better delta(t); less pumping energy
- Integration with IBM's OpenBMC provides information necessary to protect ~37K CPUs and GPUs from inadequate flow across the cold plate.



 Integration with the scheduler allows us to correlate power and temperature data with individual applications

South Computing Research Computing FACILITY

Summit's Power Demand, Aug 2018– Aug 2019

CNati



Detailed Analysis of Summit's Annual PUE



Summit's RM Challenge – Data Volume

- Data Streams Include:
 - IBM OpenBMC framework (99 metrics/node/second x 4608 nodes = ~460,000/sec) OOB
 - IBM LSF jobs data for running applications (~10sec update interval)
 - NOAA weather/wet bulb for Oak Ridge area (continuous, external)
 - Programmable Logic Circuit (PLC) water flow (continuous, protected as part of BAS)

TOTAL ~470,000 metrics per second available for real-time analytics

Sample from Grafana Dashboard (live version shown)



MTW Performance

2018:Supply 70°F & ~4500GPM 2019:Supply 71°F & ~3300GPM



Year over Year, 2018 to 2019:

- IT Demand (kW-h) is up 19%
- CHW use is 39% LESS than in 2018
- The one-degree adjustment of supply temperature provided a savings of \$40,000

```
COAK RIDGE LEADERSHIF
National Laboratory
```

Summit (System) Impact:

- No substantive impact to CPU or GPU operating conditions (junction temperatures)
- One degree increase in room temperature (worst case about 72.5° F)

Summit Power/Jobs Every Second



Click to Play Movie

CAK RIDGE

Summit Temperature/Jobs Every Second



Click to Play Movie

Southernoise Content of Content o

